

To: Egan, Robert[egan.robert@epa.gov]
From: Hanson, Kristen
Sent: Mon 12/29/2014 3:45:51 PM
Subject: RE: TO 1019 Tower Standard analytical results

Good Moring Bob,

Do you have results from the last three samples collected on November 25th? Also, is there a summary report?

Kristen

From: Egan, Robert [mailto:egan.robert@epa.gov]
Sent: Wednesday, December 10, 2014 1:34 PM
To: Hanson, Kristen
Subject: FW: TO 1019 Tower Standard analytical results

Hi Kristen,

Here are the lab results from the private well sampling performed on 11/13/2014. Lead was high at the second well location sampled on 11/13, which I believe was the Tribal office on Hwy 70 (14284 Hwy 70W). I remember the folks at the office stating that they don't drink the water. That is good because it exceeds the MCL of 15 ppb by a substantial amount. Other wells had lead detects but all were below 1 ppb.

No other detects were reported from any of the samples. Please inform the workers at the office location that they should refrain from drinking the water until we can confirm the results with our next round of samples.

Please let me now if you have any questions.

Bob Egan

Corrective Action Manager

Underground Storage Tanks Section

RCRA Branch

(312) 886-6212

(312) 692-2911 (fax)

From: Sharp-Dahl, Julie [<mailto:jsharp-dahl@bristol-companies.com>]

Sent: Wednesday, December 10, 2014 12:01 PM

To: Egan, Robert

Cc: Ruth, Scott; DePont, Lynn

Subject: TO 1019 Tower Standard analytical results

PLEASE NOTE THAT EPA AND CONTRACTORS ARE RECEIVING THIS EMAIL.

Hi Bob,

Attached are the tap water analytical results and field forms from the Tower Standard sampling event. I did a quick review of the data and it is usable as presented in the lab report. The results are reported to the MDL.

The only analyte detected above lab MDLs was lead. Only one tap water sample had a lead result that exceeded the screening levels presented in Table 2 of the *Private Well Sampling Plan*. The sample with the elevated lead result was collected from the second home sampled on November 13 (14284 Hwy 70 W). The lead result for this sample exceeded all screening criteria including Federal MCLs and had a reported concentration of 118 µg/L.

Please contact me if you have any questions.

Julie Sharp-Dahl

Senior Project Manager

Bristol Environmental Remediation Services, LLC

111 W. 16th Avenue, Third Floor

Anchorage, AK 99501-5109

Phone : (907) 743-9394

FAX : (907) 563-6713

jsharp-dahl@bristol-companies.com

<http://www.bristol-companies.com/>

CONFIDENTIAL NOTICE: This document is for the sole purpose of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited. If you are not the intended recipient, please contact the sender and destroy all copies of the original document.

--